


*From Reservoir to Power
Plant.*

*A unified Digital Twin for
Development and
Operation*




Holistic approach to modeling


- Optimize asset design during development
- Assure long-term, sustainable energy production



Surface- subsurface integration



Maximise power output





Optimize operations



Data quality
& data management

Surface- subsurface integration





File Home Pipe View Tools Dynamics Reporting

Case Study Model Regression Optimizer Unit Sets Settings Emissions Configuration Utilities Time-Based Analysis Command Line Convergence Monitor Line List Specification Summary Server Manager Snapshot Manager Take Snapshot Restore Last Snapshot Restore Snapshot Snapshots

Set value ..CaseOptimizerManager.OptimalOperations_BaseCase.Run = 1. Assignment type 2

Shapes Search for shapes (Ctrl+E) View

Main Shapes Material Stream Signal Stream Energy Stream Cross Connector Valve Pipe Segment

Steady State-VMGSim (Process) PFD

Power_Balance Output [MW] *45.01 Net [MW] *41.00 Overall Efficiency [%] *60.05

Steam_Turbine Power 14.9 [MW] P Ratio *3.80 Flow 248.6 [ton(metric)/h]

Motive_Fluid P *1957.0 [kPa] T 156.4 [C] ISOPENTANE 100.00 [%]

ORC_Turbine Power 30.09 [MW] P Ratio 19.27

AC1 Air Inlet T *10.0 [C] Deg Sub Cooling *4.00 [C] Fan Duty 1.963E+6 [W]

Objective Function

Active	Name	Path	Mode	Current Value	Weight	Contribution	Optimizer Value	Optimizer Contribution [Units]
<input checked="" type="checkbox"/>	Obj Fn 1	Power_Plant.Power_Balance.F10 (Overall Efficiency)	Maximize	60.05	1.00	60.05	65.74	65.74
<input checked="" type="checkbox"/>	Obj Fn 2	Power_Plant.Power_Balance.B10 (Output Power)	Maximize	45.01	1.00	45.01	49.40	49.40
<input checked="" type="checkbox"/>	Obj Fn 3	Power_Plant.Power_Balance.B11 (Net Power)	Maximize	41.00	1.00	41.00	45.24	+10%

Manipulated Variables

Active	Name	Path	Lower Limit	Current Value	Upper Limit	Spec. Status	Optimizer Value	[Units]
<input checked="" type="checkbox"/>	Manipulated Var 1	/Power_Plant.Motive_Fluid.In.P	1800.00	1957.00	2300.00	Ready	1800.00	[kPa]
<input checked="" type="checkbox"/>	Manipulated Var 2	/Power_Plant.PreHeater.Out.Shell.T	15.0	70.0	150.0	Ready	80.1	[C]
<input checked="" type="checkbox"/>	Manipulated Var 3	/Power_Plant.ORC_Pump.Pressure Ratio	10.00	30.00	30.00	Ready	30.00	
<input type="checkbox"/>	Manipulated Var 4	/Power_Plant.Vaporizer.Out.Tube.VapFrac	0.00	0.00	1.00			
<input checked="" type="checkbox"/>	Manipulated Var 5	/Power_Plant.Steam_Turbine.Pressure Ratio	1.25	3.80	20.00	Ready	4.76	

Constraints

Active	Name	Path	Lower Limit	Current Value	Upper Limit	Spec. Status	Optimizer Value	[Units]
<input type="checkbox"/>	Constraint Var 1	/Power_Plant.Vaporizer.Approach T	0.01	3.75		Missing bound(s)	0.01	[C]
<input checked="" type="checkbox"/>	Constraint Var 2	/Power_Plant.PreHeater.Approach T	0.01	44.40		Missing bound(s)	0.01	[C]
<input checked="" type="checkbox"/>	Constraint Var 3	/Power_Plant.Cooling_Water.T	10.1	12.5		Missing bound(s)	10.3	[C]

Run Finished. Convergence criteria met. Close

Shapes Simulation Tree Errors Main Flowsheet Steam_System Power_Plant All +

Windows List

90.0 C

157.9 C

PreHeater Approach T 44.4 [C] Duty 40.4 [MW] ORC Outlet T *70.0 [C]

9 C

13.9 C

Injection 58.3 [C] 69.88 [kPa]

ORC_Pump P Ratio *30.00 Energy Use 1.5 [MW]

ORC_Pump

Injection_Pump

Unified Environment for Operations for Maintenance

