

7th Thermal-Mechanical-Chemical Energy Storage Workshop
July 2025

DATA CENTERS – CAN LDES SOLUTIONS FIT THE CURRENT NEED

STRATEGIC ASSESSMENT: DATA CENTER

David K. Bellman
All Energy Consulting / Skylar Capital / SynMax / SGT Global

Datacenter

Tier 1 – 28.8 Hours Downtime per year

Tier 2 – 22 Hours Downtime per year

Tier 3 – 1.6 Hours Downtime per year



Tier 4 – 26.3 Minutes Downtime per year

Last Year

Lead times for backup diesel generators 18mth+

Economics of Datacenter is not that complicated and yes it can be very lucrative .

10 MWBuild				
Datacenter Build	\$ 360,000,000			
H100	7840	Unit		
Utilization of Datacenter	75%			
Power Price Cases \$/MWh	100	1000	2000	3000
Cost of Power	\$ 9,385,714	\$ 93,857,143	\$187,714,286	\$ 281,571,429
H100 Rental	5	\$/Hr		
Potential Annual Revenue	\$ 257,544,000			
Power % of Revenue	4%	36%	73%	109%



The PRICE is right!

They are paying north of \$150/MWh!

$$(\$240\text{Million}/(200\text{ MW} \times 8760 \times 0.9)) = \$152/\text{MWh!}$$

Helios Value Creation Opportunity

The value creation opportunity at Helios is enormous; every 200MW gross (133MW Critical IT load assuming 1.5 PUE) leased results in:

- **\$240MM of revenue** (\$1.8MM of revenue per MW of critical IT load per CoreWeave lease)
- **\$216MM of EBITDA** (90% EBITDA margin, per mgmt. guidance as lease is structured as Triple Net)
- **\$4.9MM of enterprise value** (assuming 22.5x EBITDA multiple, which represents discount to public and M&A data center comps at ~25x+)
- **\$3.4B of equity value** (assumes 80% LTC construction financing, per mgmt. guidance; 12% rate assumed for purposes of conservatism)

Note: The required equity investment is limited beyond amounts funded for the first 600MW at Helios. At stabilization, the construction loan will be refinanced out with lower cost debt, and refinancing proceeds will exceed the construction loan principal, with excess proceeds "recycled" as equity into new development

CapEx & Financing Assumptions (\$MMs) (per 200MW Gross)	
MW (Gross)	200
PUE	1.5
MW (Critical IT)	133
CapEx \$ per MW (Critical IT Load)	\$ 12
Total CapEx	\$ 1,600
Loan to Cost ("LTC")	80.0%
Construction Loan (\$)	\$ 1,280
Required Equity from GLXY (per 200MW Gross)	\$ 320

Stabilized EBITDA, Valuation, and Returns	
Rev. per MW - Critical IT Load (Year. 1)	\$ 1.8
Revenue (Year 1)	\$ 240
EBITDA Margin	90.0%
EBITDA (Year 1)	\$ 216
Assumed EBITDA Multiple	22.5x
Enterprise Value	\$ 4,860
Less: Construction Loan Principal	(1,280)
Less: Construction Loan Interest (1-yr., 12% All-In)	(154)
GLXY Equity Value (per 200MW Gross)	\$ 3,426

Galaxy has already signed up 600MW gross MW capacity on these terms, which results in ~\$650MM of expected EBITDA; Assuming a 22.5x EV / EBITDA multiple and 80% construction LTV, **the existing 600MW leased implies \$10.3B of equity value**

Total Equity Value Helios (USD)

EBITDA (\$MMs)	Gross MW	Critical IT	Estimated EBITDA Multiple										
			17.5x	18.5x	19.5x	20.5x	21.5x	22.5x	23.5x	24.5x	25.5x	26.5x	27.5x
\$ 216	200	133	\$ 2,346	\$ 2,562	\$ 2,778	\$ 2,994	\$ 3,210	\$ 3,426	\$ 3,642	\$ 3,858	\$ 4,074	\$ 4,290	\$ 4,506
432	400	267	4,693	5,125	5,557	5,989	6,421	6,853	7,285	7,717	8,149	8,581	9,013
648	600	400	7,039	7,687	8,335	8,983	9,631	10,279	10,927	11,575	12,223	12,871	13,519
864	800	533	9,386	10,250	11,114	11,978	12,842	13,706	14,570	15,434	16,298	17,162	18,026
1,080	1,000	667	11,732	12,812	13,892	14,972	16,052	17,132	18,212	19,292	20,372	21,452	22,532
1,296	1,200	800	14,078	15,374	16,670	17,966	19,262	20,558	21,854	23,150	24,446	25,742	27,038
1,512	1,400	933	16,425	17,937	19,449	20,961	22,473	23,985	25,497	27,009	28,521	30,033	31,545
1,728	1,600	1,067	18,771	20,499	22,227	23,955	25,683	27,411	29,139	30,867	32,595	34,323	36,051
1,944	1,800	1,200	21,118	23,062	25,006	26,950	28,894	30,838	32,782	34,726	36,670	38,614	40,558
2,160	2,000	1,333	23,464	25,624	27,784	29,944	32,104	34,264	36,424	38,584	40,744	42,904	45,064
2,376	2,200	1,467	25,810	28,186	30,562	32,938	35,314	37,690	40,066	42,442	44,818	47,194	49,570
2,592	2,400	1,600	28,157	30,749	33,341	35,933	38,525	41,117	43,709	46,301	48,893	51,485	54,077
2,700	2,500	1,667	29,330	32,030	34,730	37,430	40,130	42,830	45,530	48,230	50,930	53,630	56,330

800MW Gross / 533MW Critical IT Load: Total currently approved capacity at Helios; **\$13.7B** of equity value at 22.5x EBITDA multiple


1,600MW Gross / 1,067MW Critical IT Load: Includes 800MW of incremental capacity expected to be approved in "single digit months"; **\$27.4B** of equity value at 22.5x EBITDA multiple

2,500MW Gross / 1,667MW Critical IT Load: Total potential capacity at Helios (800MW approved today plus full 1,700MW under load study approval); **\$42.8B** of equity value at 22.5x EBITDA multiple midpoint

Datacenters want to be green AND want ATC reliability

Microsoft's Emissions

Artificial intelligence is putting the tech giant's climate goals under pressure



Source: Microsoft (Scope 1, 2 and 3 "management criteria" data)
Note: Green dots represent linear decline to carbon negative goal.

Bloomberg Green

Last Year

Google Sustainability Report

ENERGY		2023		
Energy consumption	Unit	Renewable sources	Non-renewable sources	Total
Fuel	MWh	68,300	232,900	301,200
Purchased electricity ⁷	MWh	15,672,000	9,580,600	25,252,600
Purchased heat ⁸	MWh	0	278,500	278,500
Purchased steam	MWh	0	14,500	14,500
Purchased cooling	MWh	0	53,000	53,000
On-site renewable electricity	MWh	10,700	0	10,700
Total energy consumption	MWh	15,750,900	10,159,600	25,910,500

Is it possible to develop a cost-effective long-duration energy storage system that can address both short-term and long-term energy needs?

Such a system could be a game-changer if enabling facilities to achieve sustainability goals while simultaneously providing backup power capabilities.

Being Green Requires More Work


Last Year

Energy storage can play a crucial role in minimizing CO₂ emissions from a center. Data centers connected to the grid can utilize on-site storage to significantly reduce their carbon footprint and contribute to a cleaner grid.


For facilities prioritizing CO₂ reduction, strategically deploying battery storage with a capacity of approximately 12 hours a day can minimize carbon emissions.

In this scenario, the primary driver for storage adoption is not cost reduction, but rather CO₂ emissions reduction.

On-Peak Fuel Mix



TX 2023






Datacenter Map 2030





Datacenter Capacity Additions Overtime & SynMax Vulcan Coverage



Capacity and Year Online from IIR. Null represents the currently non-Vulcan covered project. Confirm notes the first satellite image shows construction signs. None notes the project does not show any construction signs - no land clearing or structure at the site.



Pryor Data Center DC 12 (Oklahoma, US)

Vulcan latest capture on **May 5, 2025**



ISO: SPP


Owner: Google, Inc.

Unit Capacity: 70 MW (DC 12), Total site capacity: 436 MW

Plant/ Unit Status: Operational

IIR Start Date: 31ST December 2024

SynMax Vulcan




Evolution Of Pryor DC 12 (Oklahoma, US)

Vulcan Latest- May 5, 2025

Building Footprint- Oct 14, 2024

Land Clearing - Jan 1, 2024

First Structures- Jun 6, 2024



SynMax Vulcan





Oriana Solar Plant (Victoria County, Texas, US)

Vulcan latest capture on **Apr 13, 2025**




ISO: ERCOT

Owner: Oriana Solar LLC

Capacity: 180 MW

Expected Online: June 2025



Evolution Of Oriana Solar Plant (Victoria County, Texas)

3
Vulcan Latest- Apr 13, 2025



1
Land Clearing - July 15, 2024



2
First Structures- Sept 27, 2024



SynMax Vulcan

SynMax.com/vulcan

SynMax Vulcan

Datacenter Bubble

The potential for a "winner-take-all" outcome is a significant driver behind the current build-out.


Annual advertising revenue for Google, Meta, and Amazon collectively stands at approximately \$460 billion.

A projected investment of \$2 trillion could potentially yield a return approaching 20% over 10 years, assuming a strategy to capture a substantial share of this market.

Current spending by publicly traded companies is around \$300 billion annually, translating to an estimated 10-15 GW of capacity per year. If this accounts for 60% of total spending, the overall market could be between 16-25 GW annually.

Infrastructure for Datacenter


Sites are being picked away – optimal site offers reliable power, fiber, and workforce.



Why AI/ML?

Case study showing the value AI/ML can bring to society:


T-PULSE assures OSHA compliance with AI/ML – 400+ Models



NERC Longterm Reliability Assessment 2024

Error in MISO found a few weeks ago.

NERC now notes MISO is not in the high risk category but elevated.



NERC Summer Assessment 2025

Summer highlights
current issues are
overall in the range
for typical outages.

Extreme conditions
cause the West and TX
and parts of MISO in
the negatives.




Table 2: Seasonal Risk Scenario On-Peak Reserve Margins

Assessment Area	Anticipated Reserve Margin	Anticipated Reserve Margin with Typical Outages	Anticipated Reserve Margin with Higher Demand, Outages, Derates in Extreme Conditions
MISO	24.7%	9.3%	-1.9%
MRO-Manitoba	14.6%	11.2%	3.8%
MRO-SaskPower	33.5%	28.3%	22.4%
MRO-SPP	28.5%	18.2%	3.4%
NPCC-Maritimes	42.2%	31.7%	18.6%
NPCC-New England	14.1%	3.9%	4.0%
NPCC-New York	31.6%	12.5%	5.2%
NPCC-Ontario	23.4%	23.4%	3.7%
NPCC-Québec	32.7%	28.2%	19.1%
PJM	24.7%	15.0%	5.3%
SERC-C	19.6%	12.7%	3.2%
SERC-E	29.1%	21.8%	13.0%
SERC-FP	20.2%	14.0%	11.8%
SERC-SE	41.3%	37.7%	12.5%
TRE-ERCOT	43.2%	33.0%	-5.1%
WECC-AB	42.6%	40.3%	20.5%
WECC-Basin	24.3%	15.9%	-27.2%
WECC-BC	24.3%	24.2%	-6.6%
WECC-CA	56.9%	51.0%	4.7%
WECC-Mex	14.1%	1.6%	-16.8%
WECC-NW	32.1%	29.4%	-13.0%
WECC-RM	25.7%	18.2%	-18.9%
WECC-SW	22.3%	14.0%	-13.0%


Peak Demand?

With solar the impact of peak demand is not as obvious.

By 9pm the solar is gone but load has also dropped off by nearly 13%.

Coincidentally the winter vs. summer peak is around 14%.

Therefore if solar exceeds 13% of total generation in peak other generation is needed by 9 pm.




Reliability


SAIDI = System Average Interruption Duration Index. It is the minutes of non-momentary electric interruptions, per year, the average customer experienced.

CAIDI = Customer Average Interruption Duration Index. It is average number of minutes it takes to restore non-momentary electric interruptions.

SAIFI = System Average Interruption Frequency Index. It is the number of non-momentary electric interruptions, per year, the average customer experienced.




2023 SAIFI



Datacenter Projects by State

Largest growth for
datacenters seen in
TX and VA

Datacenter Project 2025-2030 Map



© 2025 Mapbox © OpenStreetMap


Datacenter data from IIR

Power Plant Projects by State

A clear leader in generation projects is ERCOT.

ERCOT is more likely to be able to meet the datacenter load growth.

EIA New Build 2025-2030 Map




Datacenter Additions / Power Plant Additions

Certain states are depending on transmissions e.g. NJ and VA.

LA, GA, AL, SD, IA are using up their surplus.

However, the distribution system will also be stressed.

2025-2030 Datacenter Build / Power Plant Build




Datacenter Additions / Power Plant Additions Removing Solar

The AI datacenters are not going to shut off at night and the load drop is not enough to make up for the loss of solar in many states.

Solar builds are 47% percent of the builds till 2030.

Resource planners need to go back to the dispatch models and refine the loss of load cases.

2025-2030 Datacenter Build / Power Plant Build Remove Solar




Datacenters without signs of Construction

With datacenter constructions averaging around 2 years, we have over 36 GW not in construction yet but with an online date sooner than 2027.

VA projects likely at risk given timing and limited expansion.

Datacenter Project 2025-27 No Construction



Enough supply with the amount of load?

Gas supply chain is tight.

McKinsey notes 150 GW additional data center demand coming by 2030.


Solutions still coming from policy side - In Texas Senate Bill 6 allows utilities to curtail loads greater than 75 MW during firm load sheds.

Resource Adequacy Challenge: Gas-Fired Alone Will Not Meet the Need

Next 5 years will need new capacity for 160 GW peak growth *plus* reserve margin and replacing retirements

- Retention is important where needed and cost effective
- All new supply resources have lead times for development, equipment, construction, and interconnection
- New gas-fired generation will be limited by supply chains:
 - <80 GW in interconnection queues¹ and not all will be built²
 - Supply chains may limit development to closer to 50 GW by 2030
 - Lead times for turbines mean 50 months to build a CC, 44 for CT³
- Many more resources will be needed to meet the **gap**:
 - BESS, wind and solar
 - >2 TW ICAP in queues is vast, even if resource adequacy value is derated
 - 2025 has 18 GW BESS, 33 GW utility-scale PV, 8 GW wind planned⁴
 - Loss of tax credits will reduce builds dramatically
 - Demand side: DR/VPPs, energy efficiency... more cost effective now
 - Upgrades and restarts (though these are limited)
- Tx interconnection must be further expedited, and behind-the meter resource additions

New Gas-Fired Plants Insufficient to Meet Projected Demand



Notes: Available new gas-fired capacity does not include upgrades to existing plants; projected peak demand growth calculated from compilation of RTO and utility load forecasts; does not account for the need to replace planned retirements.

Sources: 1. LBNL, "[Queued Up: 2024 Edition](#)," April 2024
2. Rough estimate based on statements from turbine manufacturers
3. [Brattle 2025 CONE Study for PJM Quadrennial Review](#)
4. [EIA: Solar, battery storage to lead new U.S. generating capacity additions in 2025](#)

Combined Cycle Economics not Aligned with Natural Gas & Power Futures

As of 6/26/25

Cal 2027:

Henry: \$4/mmbtu

PJM W On-Peak:

\$62.95/MWh

ERCOT-N On-Peak:

\$60.72/MWh

CC LCOE Analysis


Capital Cost \$/kW	1000	2000	2000	2000	2000
Discount Rate	8	8	8	8	12
Period Year	20	20	20	20	20
Capacity Factor	65	65	50	50	50
FOM \$/kW-yr	25	25	25	25	25
VOM \$/MWh	3	3	3	3	3
Heat Rate mmbtu/MW	7	7	7	7	7
Fuel Cost \$/mmbtu	4	4	4	5	5
LCOE \$/MWh	53	71	83	90	105

Variable Impact on LCOE	\$/MWh
2X Capital Cost	18
Reduce Capacity Factor by 15%	12
Gas Price Up by \$1/ mmbtu	7
Discount Rate Increase 50%	15

Data center demand vary by type


AI Training highest utilization rates but still vary usage during the day

Figure 9: Server utilization rate by data center type



Source: BloombergNEF, Lawrence Berkeley National Lab. Note: Average utilization rate is capacity weighted.

Fig 2. Data-center energy use typically ranges from 80-125% of its daily average?



Source: Technical Papers, Company Reports, TSE

[Download the data?](#)

Volatility Solutions Needed

AI workloads are different
Even off-grid solutions still
must deal with the intra-
day/intra-hour volatility.






Figure 3:
Real-time power
consumption from
two US hyperscale
data centres (MW)



Source: Wood Mackenzie PowerRT Sensor Data

FIGURE 2.3. AI Training Power Consumption Example



New and challenging load consumption patterns have been observed particularly for AI data centers, which can pose potential grid stability and reliability risks and thus must be effectively modeled, studied, and mitigated.. SOURCE: EDGETUNEPOWER INC.

Data center energy needs

1. Time to market – its an arms race they need it now!
 - Good news: Policies are pushing for Data Center coming online fast – e.g. SPP “flexibility rule”- 90-day interconnection along as data center agrees to cut demand or transfer to back up generation when the grid is strained. ERCOT is also on track to offer something similar.
2. Energy must be there all the time when they need it! LOTS of redundancy!
Outages beyond 4 hr exist!
3. Their load can go up and down intra-hour so they need power sources that can handle that!
4. If the above can be done they would *like* it to be green....

Can your LDES technology fill this need?